

71/ABC/MN

E56

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/WZ/EH/2022/ 222

Dated: 02/03/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: - Inspection report in r/ o. The Beer café (A unit of BTB Marketing Pvt. Ltd.) Located at, TF-2A, Third Floor, Pacific Mall, Subash Nagar, New Delhi-110018.

Sir,

Please refer to your online application no.:- 2022013101393 dated. 31/01/2022 on the subject cited above. In this connection it is to inform you that the premises was inspected by officers concerned of this department on 14/02/2022 in the presence of Sh. Deepak (Team Leader) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the restaurant is running at third floor in a building comprised of 02 Basements + Ground + 04 Upper floors & projection room. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant & Terrace Pump automatic sprinklers system, MOEFA, detection system etc provided. However the following shortcomings were observed.

1. Exit signages are not provided.
2. Seating arrangements has been provided at mezzanine floor with single stair of width 75 cms. against requirement of 2 X1.5 mts.
3. The Mezzanine floor is not approved as per available sanctioned plan in the file of pacific Mall, Subash Nagar, Khayla.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/ Occupier M/s. The Beer café (A unit of BTB Marketing Pvt. Ltd.) Located at, TF-2A, Third Floor, Pacific Mall, Subash Nagar, New Delhi-110018. (Online application no.:- 2022013101393 dated. 31/01/2022)
 2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id : - (dhowestzone@gmail.com).
- 28/02/22