

C-33

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/EH/2022 /221

Dated: 02 / 03 /2022

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in)

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s Verandah by Moon Shine (Vaiban Hospitality Pvt. Ltd.) Located at Plot no-02, 3<sup>rd</sup> Floor, Road No-85, West Punjabi Bagh New Delhi-110026.

Sir,

Please refer to your online application no. 2022020801854 dated 08/02/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 16/02/2022 in the presence of Sh. Manoj (Owner) and observed that the shortcomings already communicated by this department vide letter No. F6/DFS/MS/WZ/2020/49 dated 09/01/2020 & F6/DFS/MS/MN/2021/242 dated 24/05/2021, (Copy Enclosed) is still not complied.

In view of above Shortcomings the application for Renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully

(Atul Gang)  
Director  
Delhi Fire service

4c JJP  
28/02/2022

Copy to:

1. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027.  
Email Id : - (dhowest [zone@gmail.com](mailto:zone@gmail.com)).
2. The Owner/Occupier in r/o M/s Verandah by Moon Shine (Vaibav Hospitality Pvt. Ltd.) Located at Plot no-02, 3<sup>rd</sup> Floor, Road No-85, West Punjabi Bagh New Delhi-110026.

c-7

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI**

No. F6/DFS/MS/WZ/2020/49

Dated: 09/01/2020

To,

M/s Verandah by Moon Shine,  
(Vaibav Hospitality Pvt. Ltd.)  
Plot no-02, 3<sup>rd</sup> Floor, Road No-85,  
West Punjabi Bagh, New Delhi

**Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s Verandah by Moon Shine (Vaibav Hospitality Pvt. Ltd.) Located at Plot no-02, 3<sup>rd</sup> Floor, Road No-85, West Punjabi Bagh New Delhi**

Sir,

Please refer to your letter no. Nil dated-Nil on the subject mentioned above. In this connection it is to inform you that the premises was inspected by team of officers of this department on 02/12/2019 to see the functioning of fire safety equipment's provided in the building. During course of inspection

**The following shortcomings were observed:**

1. Two Exits of 2m & 1.5 m clear width remotest to each other are not provided.
2. Two Stairs of 2m & 1.5 m clear width remotest to each other are not provided.
3. Hose Reel Hose of 30 mtrs length is not provided.
4. Hydrant with hose box is not provided.
5. Automatic Fire Alarm System is not Provided.
6. Main & stand by pumps of 2280 lpm are not provided.
7. Terrace Fire Pump of 450 lpm with 40m head is not provided.
8. Under Ground Fire Water Tank of 100000 ltrs is not provided
9. Overhead water tank of 10000 ltrs capacity not provided.
10. Jockey pump of 180 LPM found not provided.
11. Exit signage's not provided.

You are requested to send compliance report of the same under intimation to this department. FSC cannot be considered at this stage.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

Copy to; -

1. The Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Dy Health Officer, West Zone, Shivaji Enclave Rajouri Garden New Delhi-110027.

0 2 1

c/26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No. F6/DFS/MS/MN/2021/ 242

Dated: 24/04/2021

To,

24/05/2021

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit,  
Police Station, Defence Colony,  
New Delhi.

**Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s Verandah by Moon Shine (Vaibav Hospitality Pvt. Ltd.) Located at Plot no-02, 3<sup>rd</sup> Floor, Road No-85, West Punjabi Bagh New Delhi**

Sir,

Please refer to your online application no. 2020112308609 dated-09/03/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned of this department on 09/04/2021 in the presence of Sh. Pranab ori (Manager) to check the Shortcomings already issued by this deptt. Vide Letter No.F6/DFS/MS/WZ/2020/49 dated 09/01/2020.

During course of inspection, it was observed that the restaurant is running at Third Floor in a Building comprised of Basement, Stilt, Ground plus three upper floors only. However, the statuses of shortcomings are as under.

S.N.	Shortcomings	Status
1.	Two Exits of 2m & 1.5 m each clear width remotest to each other are not provided.	Not Rectified
2.	Two Stairs of 2 m & 1.5 m each clear width remotest to each other are not provided	Not Rectified
3.	Hose Reel Hose of 30 mts length is not provided.	Not Rectified
4.	Hydrant with hose box is not provided.	Not Rectified
5.	Automatic Fire Alarm System is not Provided.	Not Rectified
6.	Main & stand by pumps of 2280 lpm are not provided.	Not Rectified
7.	Terrace Fire Pump of 450 lpm with 40m head is not provided.	Not Rectified
8.	Under Ground Fire Water Tank of 100000 ltrs is not provided	Not Rectified
9.	Overhead water tank of 10000 ltrs capacity not provided.	Not Rectified
10.	Jockey pump of 180 LPM found not provided.	Not Rectified
11.	Exit signage's not provided.	Not Rectified

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. M/s Verandah by Moon Shine (Vaibav Hospitality Pvt. Ltd.) Located at Plot no-02, 3<sup>rd</sup> Floor, Road No-85, West Punjabi Bagh New Delhi.

2. Dy. Health Officer, West Zone, Shivaji Enclave Rajouri Garden New Delhi-110027.