

e6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2022/ 210

Dated: 28/02/2022

To

The Joint Commissioner of Police,
Lic/ Branch, 1st Floor, Police Station,
Defence Colony, New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Yum Yum CHA (A unit of Tusaj Lifestyle Pvt Ltd) located at Shop No -310, Second floor, DLF Promenade Mall, -3, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070.

Sir,

This has reference to your MHA Portal ID 2021112627281 dated 26/11/2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Vikram Singh, Manager on dated 18/02/2022 to ascertain the availability and operability of fire protection and fire safety measures & observed that the restaurant running at 2nd floor of DLF Promenade Mall, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070. During the course of visit following observation were observed.

1. There are two Exits available in the restaurant having width of 1.50 mtr & 1.0 mtr. The door width of second exit need to be increased 1.50 mtr as per the requirement of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR/ DFS

Copy to: -

1. M/s Yum Yum CHA (A unit of Tusaj Lifestyle Pvt Ltd) located at Shop no 310, Second floor, DLF Promenade Mall, -3, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070