



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2022/SZ/ 94

Dated: 07/03/2022

To


The Manager,
New Little Star Public School,
Village Ghitorni, New Delhi 110030.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o New Little Star Public School, Village Ghitorni, New Delhi 110030.

Sir,

This has reference with Gmail of dated 19/01/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26/02/2022 and observed that the shortcoming intimated vide letter of even no. 294 dated 23/01/2018 has yet not been complied. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

Copy to

- 1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

c/n

No. F.6/DFS/MS/School/2018/SZ/ 294

Dated: 23/11/18

To

The Manager,
New Little Star Public School,
Village Ghitorni,
New Delhi-110030

Sub.: **Reg. renewal of Fire Safety Certificate in r/o school building.**

Sir,

This is in reference with your letter No. Nil dated 06/11/2017 received through outdoor dairy No. 15220 dated 20/11/2017 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated authority of this department on 30/11/2017 in presence of Mrs. Puran Kumari (Principal) of the school to verify the compliance of fire prevention and fire safety measures required under the rules. During the inspection, it was observed that there are material changes in the building as additions/alterations have been made in the building/premises affecting the fire prevention and fire safety measures including the means of escape. The school building is now comprised of ground and three upper floors, whereas previously, NOC was issued by this department for ground and one upper floor vide letter no. F.6/MS/DFS/2006/1551 dated 11/07/2006. Hence, your request for renewal of FSC is rejected under sub rule (3) of Rule 37, in view of reasons mentioned below:

1. Single staircases having width of 1.07m found provided, against required width of 1.5m, additional staircase having width of 1.5m to be provided.
2. Additional eight nos. portable fire extinguishers (ABC/Co2), ISI marked shall require/to be provided.
3. Hose-reels not found provided, one hose-reel on each floor, shall be required.
4. Terrace level pump having discharge cap. 450 LPM with 40m Head shall be required.
5. Over-head water tank exclusively for fire-fighting cap. 10,000 ltrs shall be required.
6. Exit signage on each exit and escape route at appropriate locations shall be required.
7. Year of addition of 2nd & 3rd floor may be provided with supporting documents

In view of above shortcomings, renewal of FSC cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further consideration in the matter.

Yours faithfully,


Vipin Kental
Chief Fire Officer

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

h.
ok