

e 20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/EH/NDZ/2022/233

Dated: 08/03/2022

To

The Manager,  
M/ S Burger King (Burger King India Ltd.),  
New Delhi DMRC Metro Station  
New Delhi.

Sub: Regarding grant of FSC in r/o M/S Burger King (Burger King India ltd.) situated at New Delhi DMRC Metro Station, New Delhi.

Sir,

This has reference to online ID No. 2022021402144 dated 14/02/2022 on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 25/02/2022 in the presence of Sh. K.K.Jain and observed that building plan as uploaded on the portal do not show second staircase, however, the same is available on the site.

In view of above, the Fire Safety Certificate (FSC) cannot be issued. Therefore, you are requested to upload the correct building plan and re-submit for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
DIRECTOR

Delhi Fire Service



Copy to :-

The Dy. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.