

c-55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/EH/NDZ/2022/ 191

Dated: 04.03.2022

To

The Manager,
M/S Chopra International Guest House,
4060, Kaseruwan, Pahar Ganj, New Delhi.

Sub: Regarding grant of FSC in r/o M/S Chopra International Guest House, 4060, Kaseruwan, Pahar Ganj, New Delhi. ID NO. 2022010500305 dated 05.01.22.

Sir,

This has a reference to online ID No. 2022010500305 dated 05.01.22 & email hotelchopra.int@gmail.com dated 06.01.2022. on the subject cited above, it is to inform you that the site was visited by the officer concerned of this department on dated 28.02.22 in presence of manager and following shortcomings were observed: -

- 1) Terrace pump is not provided with auto start provision.
- 2) PA system is not provided.
- 3) Building plans is not signed by owner himself.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcoming for further consideration in the matter.

Yours faithfully


373122

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.