

C-62

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No.F6/DFS/MS School/SZ/2022/ 85

Dated: 25/02/2022

To

The Principal,
DAV Public School,
Plot no. 3, Pocket 06, Jasola Vihar, New Delhi-25.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **DAV Public School, Plot no. 3, Pocket 06, Jasola Vihar, New Delhi-25.**

Sir,

With reference to email letter dated 24.01.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.02.2022 in the presence of Mr. Jeevan Singh (Superintendent) and it was observed that the building is comprised of basement + ground + 3 upper floors. During the inspection following shortcomings were observed:-

1. 02 nos. of hose reels provided in place of requirement of 04 nos. hose reels at each floor.
2. MOEFA found non functional.
3. Automatic sprinkler systems found non functional at basement.
4. Down comer system found non functional.
5. Fire pump & jockey pumps found non functional.
6. Overhead tank 10,000 liters provided in place of requirement of 20,000 liters (exclusively for fire fighting).
7. The use of basement is not as per the sanctioned plan (Multipurpose hall with stage was found operational in basement). The applicant may re-submit the plan through building department of South DMC for consideration from fire safety point of view.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

o/c 
24/2/22