

c 9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DRS/MS/11/2022/205

Dated 28/02/2022

To
The Joint Commissioner of Police (J.C.),
Police Station, Defence Colony, 1st floor,
New Delhi

Sub: Regarding issuance of Fire Safety Certificate in respect of M/s. Haldiram Bhujjiawala Inc. located at shop No. A-94 4, G.F. Wazirpur Industrial Area, New Delhi- 110052.

Sir,

Please refer to the online application ID-2022020401647 received through MHA portal regarding the subject cited above. In this connection, it is to inform you that the building has been inspected by the officer concerned of this department to check the status of the fire safety & means of escape arrangement required as per law/code.

During the course of inspection, it was observed that the restaurant is running at ground floor only in a building comprised of basement, ground plus two upper floors. No fire safety arrangements found provided in the premises. Following shortcomings were observed: -

1. Two exits having width 1.70, 0.89 mts are provided against required of 02 exits having width of 1.5 mts each.
2. Overhead water tank capacity 20,000 lts is not provided.
3. Exit signages are not provided.
4. MOEFA is not provided.
5. Terrace pump capacity 450 LPM is not provided.
6. Down comer system is not provided.
7. Hose reel hose is not provided.
8. Fire extinguishers are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully


(Ashok Aggarwal)
Director

Delhi Fire Service

Copy to:-

1. Sh. Ashok Kumar Aggarwal, M/s. Haldiram Bhujjiawala Inc. located at shop No. A-94 4, G.F. Wazirpur Industrial Area, New Delhi- 110052.
2. The DHO, Keshav puram Zone, North DMC, Kesav Puram, Wazirpur, New Delhi.