

17 Nov
C-94

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2022/194

Dated: 04/12/2022

To,

The Manager,
Hare Rama Guest House,
T-416 & T-298, Main Bazar,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hare Rama Guest House located at T-416, & T-298, Main Bazar, Pahar Ganj, New Delhi. Online ID No. 2021101123947 dated 12.10.21.

Sir,

This has reference to on line ID No. 2021101123947 dated 12.10.21 < anup khanna974@gmail.com dated 08.02.2022, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/02/2022 in the presence of Sh. Galid (Manager) and following shortcomings were still not complied :-

1. Hose reel found nonfunctional.
2. Pump not in auto start mode provision.
3. PA system found nonfunctional.
4. Building plan is also not signed by the owner /occupier.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


3/13/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.