

CS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2022/WZ/223

Dated 02/03/2022

To

The Manager
M/s JBR Foods LLP,
A-25, Ground floor, GTK Road,
Industrial Area, Delhi-110033.

Sub: - Regarding issuance of fire safety certificate in r/o M/s JBR Foods LLP locate at A-25, Ground floor, GTK Road, Industrial Area, Delhi-110033.

Sir,

This has reference to your online portal I. D. No. 2022012201108 dated 04.02.2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19.02.2022 in the presence of Mrs. Neelam (Partner) to verify the fire safety measures installed in the building and observed that the building is comprised of ground and 03 upper floors and the restaurant is running at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Smoke ventilation systems not provided.
2. Fire check door not provided.
3. Fire extinguisher not provided.
4. Hose reel hose not provided.
5. MOEFA System not provided.
6. Internal hydrants not provided.
7. Terrace level fire pump capacity of 450 lpm not provided.
8. Overhead water storage tank capacity of 20,000ltrs for firefighting purpose not provided.
9. Exit signage not provided in the building.
10. Highly combustible material foam and plastic fencing use in all around seating area which needs to be removed.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully


(Anil Garg)
Director

PH: 011-23414000

Copy to:-

1. The Dy. Health Officer, NDMC, Keshav Puram Zone, Block A-1, Keshav Puram, Delhi-110039.
2. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049.
3. The Manager, M/s JBR Foods LLP locates at A-25, Ground floor, GTK Road, Industrial Area, Delhi-110033.