

C-9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/228

Dated 04/03/2022

To

The Dy. Health Officer,
Public Health Officer,
SDMC, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Jubilant Foodworks (Dominos Pizza) located at Shop No13, GF & FF, Local Shopping Center, Saket, New Delhi 110017.


Sir,

This has reference to your MHA Portal ID No. 2022010800485 dated 08/01/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.02.2022 in the presence of Mr. Sanjeeet Singh (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at Ground and First floor only. During inspection, following points were observed:

- 1 There is one staircase having width of 1.25 mtr against the required width of 1.50 mtr each.
- 2 There are two exits having width of 1 mtr each against the required exits width of 1.50 mtr each.
- 3 First Aid Hose reel hose not provided.
- 4 Internal Hydrants not provided.
- 5 Terrace level Fire Pump capacity of 450 LPM not provided.
- 6 Overhead tank capacity 20,000 ltrs not provided.
- 7 Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR / DFS
Ouk

Copy to:

1. The Authorized Signature M/s Jubilant Foodworks (Dominos Pizza) located at Shop No13, GF & FF, Local Shopping Center, Saket-3, New Delhi 110017.