

68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/ *EH/224*

Dated:- *02/03/2022*

To

The Manager,
M/S Juggernaut (Juggernaut Gardens of Earth Private Limited.),
DMRC, PD Area, Barakhamba Road, Ground Floor,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Juggernaut (Juggernaut gardens of Earth Private Limited.), DMRC, PD Area, Barakhamba Road, Ground floor, New Delhi. Online ID No. 2021122929562 dated 20.01.22 & 2021123129668 dated 31.12.21.

Sir,

This has reference to Online ID No. 2021122929562 dated 20.01.22 & 2021123129668 dated 31.12.21 on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 02/02/202 in the presence of Sh. Vikas Kumar and following shortcomings were observed: -

1. The building plan as uploaded does not have area details, address & name of the establishment, Owner signature and signature of certified architect /empanel engineer etc
2. MCP/MOEFA is not provided.
3. The Exit Signages not provided.
4. Hose Reel/ Hydrant found non-functional.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

[Signature]
02/03/2022
(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony, Police Station, New Delhi.