

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/ 206

Dated: 28/02/2022

To

The Dy. Health Officer, (South Zone)
Public Health Department, SDMC
Aurobindo Marg, Green Park,
New Delhi -110016

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Punjab Restaurant located at property no 3 & 4, Ground Floor, Yusuf Sarai, New Delhi 110016

Sir,

This has reference with MHA Portal ID 2022020301598 dated 05-02-2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10-02-2022 to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

1. There is one exit having width of 1.25 mtr against the required of two exits having width of 1.50 mtr each.
2. First Aid Hose Reel Hose not provided.
3. The MOEFA system is not provided.
4. Internal Hydrant not provided.
5. Terrace level Fire Fighting pump capacity 450 LPM not provided.
6. Overhead tank capacity 20,000 ltrs not provided.
7. Exit Signage not provided.
8. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR /DFS

Copy to: -

1. M/s Punjab Restaurant located at property no 3 & 4, Ground Floor, Yusuf Sarai, New Delhi 110016