

c-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/92

DATED: 04/03/2022

To,

Sh. Hoshiyar Singh (Principal)<mcpsdwarkasector21@gmail.com>
SDMC Primary School (ID 1757221)
Dwarka Sector – 1/II,
New Delhi – 110075

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in
r/o SDMC Primary School (ID 1757221) Located at Dwarka Sector – 1/II, New Delhi - 110075.

Sir,

Please refer to your Email Dated 03-02-2022 on the subject cited above. In this connection it is
to inform to you that the above said building has been inspected by the officer concerned of this
department on 25/02/2022 in the presence of Ms. Rita Mishra (Incharge)

During the course of inspection followings shortcoming have been observed:-

1. Width of class room doors found less than 1.2 m.
2. Two numbers ABC type Fire Extinguishers of 5 Kg capacity at each floor found not provided.
3. Hose reel hose found nonfunctional.
4. Terrace pump of 450 lpm found not provided.
5. Over head Fire water storage tank of 8000 litres capacity found provided against required 10,000
ltrs capacity.
6. Exit signages found not provided.

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054