

c.50

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 86

Dated: 25/02/2022

To,


The Principal,
Titiksha Public School,
Sector-11, Rohini,
Delhi-110085,

Sub: Issue of FSC in r/o Titiksha Public School, Sector-11, Rohini, Delhi-110085.

Sir,

Kindly reference to online mail dated 12.12.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 453 dated 01.09.2021 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 01.09.2021 for further consideration in this matter.

Yours Faithfully


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel; -01123414250



246

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 453

Dated: 01/09/2021

To,
The Principal,
Titiksha Public School,
Sector-11, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Titiksha Public School, Sector-11, Rohini, Delhi-110085.


Sir,

Kindly reference to online e-mail dated 15.06.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **11.08.2021**, in presence of **Sh. Rakesh Solanki (Estate Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Staircase is provided with locking gates without key near by.
2. Water tank on terrace are provided with domestic connection.
3. Terrace pumps are provided but not functional.
4. One additional block found constructed making from ground to 3rd floor making building E shaped than Building plans approved by this department for C shaped building. Therefore, you are requested to provide the building plans on scale of 1:100 through building authority for further consideration in this matter.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

o/c
my