

c-63

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/EH/NDZ/2022/188

Dated:-03/03/2022

To

The Manager,
M/S Vansh Place Guest House,
960-961, Gali Kumarhan, Pahar Ganj, New Delhi.

Sub: Regarding grant of FSC in r/o M/S Vansh Place Guest House, 960-961, Gali Kumarhan, Pahar Ganj, New Delhi ID NO. 2022020801853 dated 10.02.2022.

Sir,

This has a reference to online ID No. 2022020801853 dated 10.02.2022.on the subject cited above, it is to inform you that the site was visited by the officer concerned of this department on dated 24.02.22 in presence of manager and following shortcomings were observed: -

- 1) First aid hose reel found nonfunctional.
- 2) Terrace pump of 220 LPM capacity is required against the provision of booster pump.
- 3) Terrace pump is not provided with auto start provision.
- 4) Over head fire tank of 2500liter is required against the providing of 2000 liter.
- 5) 4th floor was using as a guest room which is not allowed.
- 6) Building plans is not signed by empaneled architect/engineer and owner himself.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcoming for further consideration in the matter.

Yours faithfully



(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.