

C-102A
C-47

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/SZ/ 232

Dated: 08/03/2022

To

The Dy. Health Officer,
Public Health Officer,
SDMC, South Zone,
Green Park, Delhi 110016.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Waves Restaurant (A Unit of Cuisine Craft Hospitality Pvt. Ltd) at A-4, Sarvodaya Enclave, Aurobindo Marg, New Delhi-110017.

Sir,

This has reference to your MHA Portal ID No. 2021112927440 dated 30.11.2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 18.02.2022 in the presence of Mr. Hira Lal to verify the fire safety measures installed in the building and observed that building is comprised of basement, ground plus three but restaurant running at ground floor only. During inspection, following points were observed:

1. There are two doors having width of 1.0 mtr & 0.90 mtr against the required width of 1.50 mtr & 1.25 mtr respectively.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:

1. M/s Waves Restaurant (A Unit of Cuisine Craft Hospitality Pvt. Ltd) at A-4, Sarvodaya Enclave, Aurobindo Marg, New Delhi-110017