

c-5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/EH/NDZ/2022/ 229

Dated: 04.03.2022

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- **2022021001985** in r/o **Xero Degrees (Kiah Associates)**
situated at 35/1, B-Block, Guru Nanak Pura, Laxmi Nagar, Delhi-92.

Sir,

This has a reference to online application ID No.- **2022021001985** dated 14.02.2022 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 24.02.2022 in the presence of Mr. Lalit (Manager) and observed that building comprised of ground + 01 upper floors, ground (Restaurant), 1st floor (locked) and following shortcomings were observed at site.

1. Main exit doors width of 1.10 meter and back door exit width of 1.80 meter through 0.95 meter narrow instead width of 1.5 meter.
2. Fire check door not provided.
3. Hose reel not provided.
4. MOEFA not provided.
5. Hydrant not provided.
6. Pump 450 LPM not provided.
7. Overhead tank of capacity 20,000 liters not provided.
8. Exit Signage not provided.

In addition to above the application needs correction in respect of number of staircase, width of staircase, width of door and height of the building. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate.

Hence the application is rejected.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service



Copy to:-

The Manager,
Xero Degrees (Kiah Associates),
35/1, B-Block, Guru Nanak Pura, Laxmi Nagar, Delhi-92.