

C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 99

Dated: 09/03/2022

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
L-Block, Shastri Nagar,
New Delhi-110052

Sub: - Regarding Issuance of Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya, L-Block, Shastri Nagar, New Delhi-110052(School ID-1208095)

Sir,


Please refer to your Email dated 03/02/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 23/02/2022 in presence of Sh. Khushal Singh Negi (Estate Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running at Ground plus three upper floors in a building is comprised of Ground plus Three upper floors. However, the following Shortcomings were observed.

1. First Hose reels are provided but not functional.
2. Internal Hydrants is provided but not functional.
3. Terrace fire pump of 450 lpm is provided but not functional.


In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.


08/03/2022