

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

C-49

No. F6/DFS/MS/School/WZ/2022/ 98

Dated: 09/03/2022

To,

The Principal,
S. N. Public School,
RZ- 54, Ravi Nagar, Extn.,
Khayla, New Delhi-110018.

Sub: - Regarding renewal of Fire Safety Certificate in r/o S. N. Public School located at RZ- 54, Ravi Nagar, Extn. Khayla, New Delhi-110018.

Sir,


Please refer to your dated 04/02/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 24/02/2022 in presence of Smt. Neelam yadav (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running at Ground plus one upper floor in a building is comprised of Ground plus one upper floor. However, the following Shortcomings were observed.

1. First Hose reels are provided but not functional.
2. Terrace fire pump of 220 lpm is provided but not functional.
3. Over head water storage tank capacity of 2500 ltrs is found removed.
4. Exit signages are found removed.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully



(Dharampall Bhardwaj)
Dy. Chief Fire Officer
West Zone

1/2
08/03/2022

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.