

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2022 /117

Dated: 14/03/2022

To

The Principal,  
Nigam Pratibha School,  
Ludlow Castle Club Road,  
Civil Line, Delhi 110054.

Subject:-Regarding issuance of Fire Safety Certificate in r/o Nigam Pratibha School, Ludlow Castle Club Road, Civil Line, Delhi 110054.

Sir,

This has reference to your letter no nil dated 04/02/2022 received through outdoor diary no 6350 dated 08/02/2022 on the subject cited above, it is informed that the Fire Safety Certificate had been issued by this department vide letter no. F6/DFS/MS/School/2014/NDZ/337 dated 20.03.2014 for **Ground floor only (Tin Shed)**. The School building was re-inspected by Assistant Divisional Officer (SPM) from this department on dated 28.02.2022 and it was observed that now the building is comprised of ground + 02 upper floors. Hence it is a case of addition /alteration in the school building.

You are requested to submit your case with as built/sanctioned plan (with section and elevation plan) of the occupancy/premises through concerned building sanctioning authority in 1:100 scale. The fire safety arrangements as per NBC-Part-IV -2016 are also required to be marked on the plan.

You are requested to submit the above said plans at the earliest for further necessary action.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service  
Tel:-011-23414000

09/03

**Copy to:-**

1. The Directorate of Education, North Delhi Municipal Corporation, City S.P. Zone, Old Hindu College, Kashmiri Gate, Delhi- 110054