

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2022/WZ/ 115

Dated: 14/03/2022

To,

The Principal,
Avadh Public School,
E-Block, 40 Foot Road, Prem Nagar-III, Kirari,
Delhi-110086.

Sub: Issue of FSC in r/o Avadh Public School, E-Block, 40 Foot Road, Prem Nagar-III, Kirari,
Delhi-110086.

Sir,

This is in reference to your letter No. 03/21 dated 14.12.2021 received through outdoor diary no. 5214 dated 14.12.2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **18.01.2022**, in presence of **Sh. Ram Sagar Shukla (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. 4.5m accessible road provided against the required width of 6.0m.
2. The width of Staircase is 1.20 & 0.93 mtr against the required width of 1.50 mtr.
3. Terrace Fire pump with capacity 450 LPM is provided but not functional.
4. 5000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
s/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully


(Atul Garg)
DIRECTOR

Ph; 011-23414000

