

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2022/School/109

Dated. 14/03/2022

To,

Principal,
Bhai Joga Singh Public School,
D-4, Faiz Road, New Delhi.

Sub: Regarding Issuing of FSC in r/o Bhai Joga Singh Public School, D-4, Faiz Road, New Delhi. (Gr. + 03 Upper floor)

Sir,

This has reference to your mail id mgtbjsps@gmail.com dated 05/03/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 07/03/2022 in the presence of Ms. Sadhika Teji and the following shortcomings were observed:-

1. Back side staircase found blocked /locked.
2. No.of fire extinguishers required are 22nos, whereas only 06 extinguishers are provided.

Hence, FSC cannot be considered at this stage.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi.