

216

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/MN/ 2022 /107

Dated: 14/03/2022

To

The Principal,
Bhai Biba Singh Khalsa Public School,
Moti Nagar, New Delhi – 110015.

Sub: - Regarding issuance of fire safety certificate in r/o Bhai Biba Singh Khalsa Public School, Moti Nagar, New Delhi-110015.

Sir,


Please refer to your Email dated 03/02/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 24/02/2022 in presence of Sh. Parminder Pal Singh (Manager) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ /2629 dated 19/06/2018.

During inspection, it has been observed that the said School is running at Ground plus one upper floor in a building is comprised of Ground plus Three upper floors. (Another school Namely Guru Nanak Public School is running at 2nd floor & 02 rooms on terrace as store.) The Status of shortcomings is as under.

S. no.	Shortcomings	Status
1.	Only one stairs of 1.14 mtr. Width is provided. The width of the stair must be increase up to 1.5 mtr. or an additional staircase of 75 cms. clear width must be provided.	Not- Rectified
2.	Exit signage's found not provided.	Not -Rectified


In view of above the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The education authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

o/c

09/03/2022