## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HÈADQUARTERS: DELHI FIRE SERVICE: NEW DELHI–110001

F.6/DFS/MS/EH/2022/SZ/ 238 No.

Dated: 10/03/2022

C. 8

The Public Health Officer, Central Zone, SDMC, Jal Vihar, Lajpat Nagar, New Delhi – 110024.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Cafe Belmonte (A UNIT OF DELEAT FOOD AND BEVERAGES PVT LTD) located at K-107, B Entire Ground, Kalkaji, New Delhi 110019

Sir,

To

This is in reference to with <u>MHA Portal Id 2021103025578 dated 14/12/2021</u> on the subject cited above. The premise was inspected by the concern nominated authority of this department on 25/02/2022 in presence of Mr. Yogesh Gupta (Adv.) & observed that the building is comprised of Basement, Stilt, Ground + Three upper floor but restaurant running at Ground floor only. During the course of inspection, the following shortcoming observed were noticed:-

- 1. There are two Staircases having width of 1.60 mtr & 0.80 mtr against the required width of 1.50 mtr each.
- 2. There are two exits having width of 1.60 mtr & 0.80 mtr against the required width of 1.50 mtr each.
- 3. First Aid Hose reel hose not provided.
- 4. Automatic fire detection & alarming system not provided.
- 5. MOEFA not provided.
- 6. The Internal Hydrant not provided.
- 7. Terrace level Fire Pump capacity of 450 LPM not provided.
- 8. Overhead tank capacity 20,000 ltrs not provided.
- 9. Exit Signage not provided.
- 10. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully DIRECTOR /I

Copy to: -

1. M/s Cafe Belmonte (A UNIT OF DELEAT FOOD AND BEVERAGES PVT LTD) located at K-107, B Entire Ground, Kalkaji, New Delhi 110019