

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/ 100

Dated: 11/03/2022

To

The Principal,
Kamla Nehru Govt. Sarvodaya Kanya Vidyalaya,
Jangpura, New Delhi-14.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Kamla Nehru Govt. Sarvodaya Kanya Vidyalaya** located at **Jangpura, New Delhi-14.**

Sir,

With reference to email dated 26.02.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.03.2022 in the presence of Mrs. Neeru Sharma, Hos and it was observed that the school building is comprised of ground + 2 upper floors. During the inspection following shortcomings were observed:-

1. First-aid-hose reels found non functional
2. Fire pump having capacity 450 LPM & head 35 mtrs. found non functional.
3. Overhead water tank 10,000 ltrs must be segregate for fire fighting.
4. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)

Dy. Chief Fire Officer

Delhi Fire Service

etc 11/03/22

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.