

e-6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2022/SZ/ 237

Dated: 10/03/2022

To

The Dy. Health Officer, (South Zone)
Public Health Department, SDMC
Aurobindo Marg, Green Park,
New Delhi -110016

Sub: Issue of Fire Safety Certificate in r/o M/s Mary Lou (A unit of Nine Capital) Ground floor, Shop No 149, Plot No A-4, District Centre, Press Enclave Road, DLF Avenue, Saket, New Delhi -110017


Sir,

This is in reference to with MHA Portal ID 2022012501214 dated 25/01/2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Sh. Manveer Singh (Manager) on 23/02/2022 & observed that the restaurant running at ground floor only. During the course of inspection, the following shortcoming observed were noticed:-

1. There is one exit having width of 1.20 mtr against the required two exits having width of 1.50 mtr each.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


19/03/2022
(ATUL GARG)
DIRECTOR/ DFS
SM

Copy to: -

1. M/s Mary Lou (A unit of Nine Capital) Ground floor, Shop No 149, Plot No A-4, District Centre, Press Enclave Road, DLF Avenue, Saket, New Delhi -110017

5-1-2022