

e15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/School/104

DATED: 14 / 03/2022

To,

Dr. Sheetal Mann (Principal) <modernconventschool@rediffmail.com>
Modern Convent School,
Sector – 4, Dwarka New Delhi -110078.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Modern Convent School, Located at Ground+3 Upper Floors Sector – 4, Dwarka New Delhi -110078.

Sir,

Please refer to your Email Dated 18-02-2022 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 24/02/2022 in presence of Dr. Sheetal Mann (Principal).

During the course of inspection followings shortcoming have been observed:-

1. The width of entry gate found less than 6mtr.
2. Six m internal road around the building found not provided.
3. Fire Check Doors found not provided.
4. Width of Class room doors are less than 1.2 mtr required width at 4th floor
5. Smoke management system not interlinked with MOEFA in basement.
6. Manually operated fire alarm system (MOEFA) found not provided at 4th floor
7. Public address system not extended to 4th floor.
8. Main pump of 2280 lpm jockey pump of 180 lpm and standby pump of 2280 lpm at ground level found not provided.
9. Under Ground Fire water storage tank of 50000 litres capacity found provided against required 2,00,000 ltrs capacity.
10. Exit signage found not provided.
11. Pressurization of Lift Shaft found not provided.
12. PA System Panel, Battery backup & Building Floor Plans in fire control room found not provided.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054