

c-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2022/ 101

Dated: - 11/03/2022

To.

The Incharge,  
NDMC Primary School,  
WEA, Channa Market, Karol Bagh,  
New Delhi- 110005.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o NDMC Primary School, WEA, Channa Market, Karol Bagh New Delhi- 110008.

Sir.

With reference to your letter No. nil dated 10.02.2022 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 23.02.2022 in presence of Mrs. Babita, Incharge, to check the fire safety arrangements provided in the school building.

During the inspection, it was also observed that the school building is comprised of ground plus two upper floors. The upper floors are served by 02 nos. of staircases having width 1.50mts each. Fire safety arrangement such as fire extinguishers, overhead water tank etc. found provided. This department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/SZ/2018/5029 dated 14.02.2018. However following shortcomings were observed: -

1. Terrace pump capacity 450 Lpm is required.
2. First Aid Hose Reel is required at each floor.

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. This department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/SZ/2018/5029 dated 14.02.2018. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

  
(Sunil Chaudhary)

Dy. Chief Fire Officer  
South Zone

Copy to: -

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi- 110054 .

For information please