

C-100

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/2022/ 206

Dated:-10.03.2022

To

The Manager,
M/S Sapna Guest House,
5131-33Main Bazar, Pahar Ganj,New Delhi.

Sub: Regarding grant of FSC in r/o M/S Sapna Guest House, 5131-33, Main Bazar, Pahar Ganj, New Delhi. ID NO. 2022021102017 dated 11.02.2022.

Sir,

This has a reference to online ID No. 2022021102017 dated 11.02.2022 on the subject cited above, it is to inform you that the site was visited by the officer concerned of this department on dated 23.02.22 and observed that there is a addition of 02 guest rooms at first floor and following shortcomings were observed: -

1. One staircase of .90 meter is provided, whereas 02 staircase of 1.5 meter each is required as per UBBL-2016.
2. Width of corridor is provided .90 meter against the requirements of 1.5 meter.
3. Undertaking regarding not to use any floor above second floor is required to be submitted as mezzanine is counted as a floor.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcoming for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to :-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.