

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2022/ 210

Dated:-10/03/2022

To,
The Manager,
Shervani Fort View,
11, Sunder Nagar, New Delhi.

Sub: Renewal of FSC (Fire Safety Certificate) in r/o M/S SHERVANI FORT VIEW, 11 Sunder Nagar, New Delhi ID No. 2021090920746 dated 09.09.2021.

Sir,

This has reference to your e-mail accounts@shervanihotels.com dated 10.02.2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 28.02.2022 in the presence of Mr. Harish Sharma and following shortcomings were observed: -

1. Hose reel found non functional.
2. Pump found non functional.
3. Further, Fire Check Door of 01 hr. rating on the staircase are required to be provided after 31.03.2022 as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,


10/3/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.