

C 20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

No. F6/DFS/MS/School/WZ/2022 / 108  
To,

Dated: 14/03/2022

The Principal,  
Shivani Public School,  
Nangloi, Delhi-110041

**Sub.:- Renewal of Fire Safety Certificate in r/o Shivani Public Sr. Sec. School, Located at Nagloi, Delhi-110041.**

Sir,

Please refer to your letter no. nil dated 22.01.2022 on the subject cited above. In this connection it is to inform you that the said School building have been inspected by the officer concerned of this department on 14.02.2022 in the presence of Sh. Sumeet Sharma (Principal) and observed that the earlier school building was issued fire safety certificate vide letter no. F6/DFS/MS/School/WZ/1286 dated 28.08.2017 for Ground + 02 Upper Floor. The management has added one more upper floor & now the school building is comprised of Ground + 03 Upper floors. Fire safety arrangements such as fire extinguishers, terrace pump capacity 450 LPM, first aid hose reel hose etc. Found provided. However, following shortcomings were observed:-

1. Three staircases having width 0.89, 0.97 & 1.04-1.13 mts are provided from ground floor to third floor instead of required width 1.5 mts each from second floor to third floor, being the new construction.
2. Door size is provided 1.04 m at 3<sup>rd</sup> floor instead of required width 1.2 m.
3. Overhead water tank for firefighting exclusive is 5000 ltrs. Capacity is provided instead of requirement 10,000 ltrs. capacity for fire fighting.
4. Exit Signages are not provided.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.

10/3/22.