

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/ 103

Dated: 11/03/2022

To

The Principal,
Shyama Prasad Vidyalaya Sr. Sec. School,
17- A, Lodhi Estate, New Delhi - 110003.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Shyama Prasad Vidyalaya Sr. Sec. School located at 17- A, Lodhi Estate, New Delhi - 110003.**


Sir,

With reference to letter no. SPVES/GB/34/04 dated 03.01.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.03.2022 in the presence of Mrs. Suman Doval, Principal and it was observed that the building is comprised of three blocks: Main Blocks - (ground + 01 upper floor), Dr. Bidhan Chandra Roy Memorial Science Block - (ground + 01 upper floor) and Office cum Nursery Block - (ground floor with double height). During the inspection following shortcomings were observed:-

1. Alternate staircase having width not less than 0.75 mtrs must be provided in Science block.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

ofc [Signature]
10/3/22

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.