

e 61

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2022/WZ/ 111

Dated: 14/03/2022

To,

St. Xavier's School,
Shahbad, Daulatpur,
Delhi - 110042

Sub: Issue of FSC in r/o St Xavier's School, Shahbad, Daulatpur, Delhi - 110042

Sir,


This is in reference to your letter No. SSS/CST/GL/39 dated 02/11/2021 received through outdoor diary no. 5211 dated 14/12/2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **11.02.2022**, in presence of **Mr. Philip (Secretary)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of Staircase is 1.50 mtr against the required width of 2.0 mtr near auditorium hall.
2. The width of door of auditorium hall on second floor is 1.40 mtr against the required width of 2.0 mtr.
3. Ground plus one upper floor Hostel building found converted into Education Occupancy & no fire protection arrangement is provided.
4. Terrace pump of 450 lpm is provided, but not functional.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Anil Garg)
DIRECTOR
Ph: 011-23414000
of e
OK