

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/2022/SZ/ 571  
To

Dated: 11/03/2022

The Executive Engineer (E)  
Electrical Division No -11,  
DDA, Vikas Sadan,  
New Delhi 110023.

Sub: Regarding issuance of No Objection Certificate in r/o EWS Housing at Plot No 14, Kalkaji, New Delhi

Sir,

This has reference to your received through Outdoor diary no 6060 dated 31/01/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26/02/2022 in the presence of Mr. Rajiv Gupta (AE)/Electrical to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The road width of all around building is less than of 06 mtr at some places.
2. Some of the staircase width is less than of 1.50 mtr.
3. The width of corridor is 1.15 mtr against the requirement of 1.25 mtr.
4. Fire check door not provided.
5. Fire extinguishers are not provided.
6. The works relates to installation of Hose Reel, internal hydrants and MOEFA is under progress.
7. Fire fighting pumps are not on auto mode.
8. Exit signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully

(ATUL GARG)  
DIRECTOR

Copy to: -

1. The Sr. Architect (SZ) DDA, Housing & Urban Project Wing, 8<sup>th</sup> Floor, Vikas Minar, New Delhi