

200  
C45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZI/216

Dated:-16..03./2022

To,

The Manager  
M/S Al-Islam Guest House,  
2158-61, Near Haj Manzil,  
Turkman Gate, Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s Al-Islam Guest House at 2158-61, Near Haj Manzil, Turkman Gate, Delhi.**

Sir,

This has reference to on line ID No. 2022020601720 dated 24.02.22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 09/03/2022 in the presence of Mr. Arshad Azmi (Manager) and following shortcomings were observed: -

1. PA system is not provided.
2. Pump was not in auto mode start provision.
3. No. of guest rooms & beds are not filled in application form.
4. Undertaking not to use any floor above third floor is also not submitted.
5. Further, compliance of gazette notification dated 27.05.2019 is also required to be provided after 31.03.2022.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
15/3/22

(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police( lic), Ist floor, Defence Colony Police Station, New Delhi.