

G 5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/D&S/MS/EH/2022/247

Dated 15/03/2022

To

The Joint Commissioner of Police (Lic.),
Police Station, Defence Colony, 1st floor,
New Delhi

Sub:-Regarding issuance of Fire Safety Certificate in respect of Mamagoto Restaurant (a unit of Purusha Hospitality) Shop No. 2F/03, Second Ground Floor, Pacific Mall, Netaji Subhash Place, New Delhi-110019.

Sir,

Please refer to the online application Online ID 2021122429272 received through MHA portal regarding the subject cited above. In this connection, it is to inform you that the building has been inspected by the officer concerned of this department to check the status of the fire safety & means of escape arrangement required as per law/code.

During the course of inspection, it was observed that the restaurant is running at second floor in a building comprised of 02 tier basement, lower ground, ground plus four upper floors. Fire safety arrangements such as fire extinguishers, first aid hose reel, internal hydrant system, overhead water storage tank capacity 20,000 lts, fire pump etc. found provided. However, following shortcomings were observed: -

1. One Exit door having width 1.36 provided against the required width of 1.5 mts.
2. Exit signages are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Sh. Anup Aggarwal, M/s. Mamagoto Restaurant (a unit of Purusha Hospitality) Shop No. 2F/03, Second Ground Floor, Pacific Mall, Netaji Subhash Place, New Delhi- 110019.
2. The DHO, Keshav puram Zone, North DMC, Kesav Puram, Wazirpur, New Delhi.