

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Restaurant/WZ/2022/ 250

Dated: 16/03/2022

To,

Narinder Kumar Walia,
House No. 239-G, Pakhowal Road,
SBS Nagar, Ludhiana,
Punjab – 141013.

Sub: Issue of FSC in r/o Dawat-E-Mehfil, GA-7 & 8, Ground Floor, Metro Walk, Sector 10, Rohini, Delhi – 110085.

Kindly reference to online application No. 2021080416813 dated 05.08.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 11/02/2022 in presence of **Sh. Ashwani Sehgal (General Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Smoke Detector system provided but not operational.
2. 04 fire extinguishers of ABC/Wco2 type provided but found empty.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

one
my