

115

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/EH/SZ/2022/ 245

Dated: 14/03/2022

To,

Sh. Shekar N Bangera (Owner),
Naivedyam Restaurant, 25/35,
East Patel Nagar, New Delhi- 110008.

Subject: - Regarding issuance of Fire Safety certificate r/o Naivedyam Restaurant, 25/35, East Patel Nagar, New Delhi- 110008.

Sir,

This has reference to the MHA Portal Id 2022021702321 dated 19.02.2022, on the subject cited above. Above said assembly building (Restaurant) was inspected by the officers concerned of this department from safety point of view on 28.02.2022 in presence of Sh. Shashi Kumar (Manager).

During the course of inspection it has been observed that the restaurants running at ground floor of a building comprised of basement, ground plus four upper floors. Fire safety arrangements only fire extinguishers found provided in restaurant. However the following shortcomings have been observed:-

1. Width of main door provided 0.94 mts against requirement of two doors width of 1.50 mts each.
2. Fire Check Door found not provided in kitchen.
3. First aid hose reel found not provided.
4. MOFEA found not provided
5. Down-comer system found not provided.
6. Terrace pump capacity 450 LPM is found not provided.
7. Overhead water Tank required capacity 20,000 Its found not provided.
8. Exit signages are found not provided.

In view of the above shortcomings, fire safety certificate cannot be considered at this stage. You are advised to rectify the above mention shortcomings and apply fresh for taking further necessary action.

Yours faithfully,


(Atul Garg)

Director
Delhi Fire Service

Copy to:-

1. The Joint. Commissioner of Police (Licensing Unit), 1st floor, Police Station, Defense Colony, New Delhi.