

C-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZ/ 119

Dated 16/03/2022

To,

The Principal,
Nigam Pratibha Vidyalaya,
Mohanpuri, Shahdara North,
Delhi 110053

Sub:- Regarding Issuance Fire Safety Certificate in r/o Nigam Pratibha Vidyalaya located Mohanpuri, Shahdara North, Delhi-110053.

Sir,

This is in reference to your letter No. EDMC/MP II/2022/01 dated 09/02/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned Nigam Pratibha Vidyalaya from fire safety point of view in presence of Mr. Ravi Kiran, HOS of the School. The building comprise of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. Only 10 fire extinguishers provided in place of 19 fire extinguishers as required.
2. First-Aid hose reels provided but not functional.
3. Terrace pump having 450 LPM output at 40 meter head provided but not functional.
4. Exit Signage were not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92

