

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2022/GH/219

Dated: 16/03/2022

To,

Mr. Rishabh Khanna,
House No.41, Ashok Vihar, Phase-I,
Delhi-110052.

Sub: Issue of FSC in r/o M/s 35th Avenue A unit of Raj Rishi Trading Pvt. Ltd. Plot No.H-3, By 35, First, Second & Third floor, Sector-18, Rohini, Delhi-85.


Sir,

Kindly reference to online application No. 2021121828849 dated 20.12.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **01.02.2022**, in presence of **Sh. Sashikant (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Alternate i.e iron staircase at third floor is not accessible.
2. CO detector system not provided.
3. Terrace Fire pump with capacity 900 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to:-

1. The Manager, (M/s 35th Avenue A unit of Raj Rishi Trading Pvt. Ltd. Plot No.H-3, By 35, First, Second & Third floor, Sector-18, Rohini, Delhi-85.