

C 39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 122

Dated: 16/03/2022

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
No-2 Madipur,
New Delhi- 110063.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, No- 2, Located at Madipur, New Delhi – 110063.

Sir,

Please refer to your Email dated 11/02/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 03/03/2022 in presence of Dr. Vandana Sharma (HOS) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running at 3 Blocks, BL-1 & BL-2 are G + 1 each & BL-3 is G + 2 upper floors. Block -1 is served by two staircases having width 1.4mtr & 1.5 mtr, Block-2 is served by two staircases having width 1.47mtr & 2.25 mtr and Block-3 is served by two staircases having width 1.25mtr, 1.28 mtr & 1.26 mtr (Iron). The following Shortcomings were observed:-

1. Fire Extinguishers are provided but found Empty.
2. First Hose reels are provided but not functional.
3. Terrace fire pump of 450 lpm is provided but not functional.
4. Exit signages are found removed.


In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.


11/03/2022