

C-8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/School/123

DATED: 17/03/2022

To,

Mr. Nirbhey Bhatia (Vice Chairman) <rajinderkennedy@yahoo.com>  
Kennedy Public School,  
RZ H-2/826, Raj Nagar-II, Palam colony,  
New Delhi – 110077.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Kennedy Public School, Located at RZ H-2/826, Raj Nagar-II, Palam colony, New Delhi – 110077.

Sir,

Please refer to your letter no Email Dated 12-02-2022 on the subject cited above. In this connection it is to inform to you that the above said building has been visited by the officer concerned of this department on 02/03/2022 in the presence of Mr. Nirbhey Bhatia (Vice Chairman).

During the course of inspection followings shortcoming have been observed:-

1. Width of class room doors found less than 1 m.
2. Hose reel Hoses found not provided.
3. The Terrace pump found not provided.
4. Overhead water storage tank of 10000 ltrs capacity found not provided

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)  
(Director)

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.