C10

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/School/NDZ/2022/ 120

Dated: 16.03.2022

To

Ms.Chand Bibi,(Principal) Utkrisht Vidyalaya Turkman Road No.2, Maharaja Ranjeet Singh, Marg, New Delhi-02.

Sub: Application for renewal of fire safety certificate in respect of Utkrisht Vidyalaya Turkman Road No.2, Maharaja Ranjeet Singh, Marg, New Delhi-02.

Sir,

This has reference to your mail id<turkmanroad2boys.cczmcd@gmail.com>dated 02.02.2022, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on dated 09.03.2022 in presence of Sh. Soumin Benerjee and observed that shortcomings issued vide letter No.F.6/DFS/MS/School/2017/2017dated 04/08/2017 have not been complied so far.

In view of above, FSC cant be renewed till the compliance of all the shortcomings issued vide aforesaid letter.

Yours faithfully,

(Dr. S.K.Tomar) Dy. Chief Fire Officer

Delhi Fire Service

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/School/2017/2017

Dated 4 18/17

To,

The Principal, Utkrisht VIdyalaya, Turkman Road No. 2, Maharaja Ranjeet Singh Marg, New Delhi – 110002.

Sub: Regarding Renewal of fire FSC in r/o Utkrisht VIdyalaya, Turkman Road No. 2, Maharaja Ranjeet Singh Marg, New Delhi – 110002.

Sir,

This has reference to your letter No. Nil Dated 17/07/2017 on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 26/07/2017 in the presence of Principal and the following shortcomings were observed:-

- 1. Hose reel not provided.
- 2. Fire pump not provided.
- 3. Overhead water tank capacity of 10,000 ltr. not provided.
- 4. Exit Signage not provided.

Hence, FSC cannot be considered at this stage.

Yours faithfully

(Sunil Chaudhary) Dy. Chief Fire Officer Delhi Fire Service

of Mi

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.