

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001 C-28

No. F6/DFS/MS/School/WZ/2022/ 131

Dated: 23/03/2022

To,

The Principal,
Shri Hanuman Sanskrit Maha Vidyalaya,
F-487/3, Raghbir Nagar,
New Delhi-110027.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Shri Hanuman Sanskrit Maha Vidyalaya, Located at F-487/3, Raghbir Nagar, New Delhi-110027.

Sir,


Please refer to your letter dated 14/02/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 03/03/2022 in presence of Smt. Neelam Nagpal (Nagpal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running at Ground plus two upper floors in a building is comprised of Ground plus Two upper floors. However, the following Shortcomings were observed.

1. First Hose reels are provided but not functional.
2. Terrace fire pump of 450 lpm is provided but not functional.
3. Over Head Water storage tank capacity of 8,000 ltrs provided against requirement of 10,000 ltrs, but not exclusively for fire fighting purpose.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully



(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

ok
11/03/2022