

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/School/WZ/2022 / 130

Dated: 23/03/2022

To,

The Principal,
Saraswati Bal Mandir School,
A-2, Paschim Vihar, New Delhi-110063.

Sub. :-Renewal of Fire Safety Certificate in r/o Saraswati Bal Mandir School Located at A-2, Paschim vihar, New Delhi-110063.

Sir,


Please refer to your email dated 10.02.2022 on the subject cited above. In this connection it is to inform you that the said School building has been inspected by the officer concerned of this department on 05.03.2022 in presence of Ms. Mamta Chauhan (Principal) to check workability/functionability of Fire safety systems provided in the building.

During inspection, the following shortcomings have been observed:-

1. First Aid Hose Reels Hose found removed at ground floor.
2. Fire Pumps are provided but found nonfunctional.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.