

c-6

33-516m

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Restaurant/2022/NDZ/ 261

Dated: 22/03/2022

To

Mr. Anil Kumar  
M/s Jubilant Food works ltd (Domino's Pizza)  
Shop no. 10, Ground Floor, Shivpuri,  
Main Patparganj Road, Delhi-110051.

**Sub.:- Regarding issuance of Fire Safety Certificate in r/o M/s Jubilant Food works ltd (Domino's Pizza) located at Shop no. 10, Ground Floor, Shivpuri, Main Patparganj Road, Delhi-110051.**

Sir,

With reference to your online application No. 2022011000551 dated 11/01/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the premises from fire safety point of view in presence of Ms. Neha, Manager of the premises on dated 21/02/2022. The building comprise of ground plus two upper floors. Proposed eating house is on ground floor. Following shortcomings were observed during the time of inspection.

1. Two doors of width 1.50mtr & 1.00mtr are provided against requirement of 1.50mtr each.
2. First Aid Hose reel is not provided.
3. MOEFA is not provided.
4. Down-Corner is not provided.
5. A Fire pump having 450 lpm output of 40 meter head at terrace is not provided.
6. Over head tank 20,000 liters is not provided.
7. Exit signage are not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

Copy to:-

The Joint Commissioner (Lic.), 1<sup>st</sup> Floor Police Station, Defence Colony, New Delhi-49.

11/1/22, 10:18 AM