

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Restaurant/2022/NDZ/ 254

Dated: 21/03/2022

To

Mr. Naveen Gupta
M/s Jubilant Food works ltd (Domino's Pizza)
Shop no. K-74 A Plot No. 74 & 76,
Chachi Building, Krishan Nagar, Delhi-110051.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o M/s Jubilant Food works ltd (Domino's Pizza) located at Shop no. K-74 A Plot No. 74 & 76, Chachi Building, Krishan Nagar, Delhi-51.


Sir,

With reference to your online application No. 2022011000607 dated 12/01/2022 on the subject cited above, team of officer of this department have carried out the inspection of the premises from fire safety point of view in presence of Ms. Neha, Manager of the premises on dated 21/02/2022. The building comprise of ground plus two upper floors. Proposed eating house is on ground floor. Following shortcomings were observed during the time of inspection.

1. Width of Alternate exit 1.5 meter not provided.
2. First Aid Hose reel is not provided.
3. MOEFA is not provided.
4. Down-Comer is not provided.
5. A Fire pump having 450 lpm output of 40 meter head at terrace is not provided.
6. Over head tank 20,000 liters is not provided.
7. Exit signage are not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

The Joint Commissioner (Lic.), 1st Floor Police Station, Defence Colony, New Delhi-49.