

C 16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2022/NDZ/ 126

Dated: 21/03/2022

To,

The Principal
Govt. Girls Sr. Sec. School,
B-Block, Meet Nagar,
Delhi-110094

Subject: -Regarding grant of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School
B-Block, Meet Nagar, Delhi 110094.

Sir,

Please refer to your letter No. GG/SS/MN/2022/148 dated 07/2/2022 on the subject cited above. In this regard, it is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department in presence of Mr. Mahesh , (Estate Manager) of the school on dated 08/03/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No.- F6/DFS/MS/School/2014/151 dated 24/01/14 are yet to be rectified. Copy of the same is enclosed for your ready reference.

Yours faithfully


21/3/22

(Dr. S.K Tomar)
Dy.Chief Fire Officer



Copy to:-

The Dy. Director of Education,
B- Block, Yamuna Vihar
Delhi-110053

c-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001
Ph-23412025, E-mail:-dcfondz.dfire@nic.in

No. F6/DFS/MS/School/2014/151

Dated 24/01/14

To,

The Principal,
Govt. Girls Senior Secondary School,
B-Block, Meet Nagar, Delhi -110094.

Subject:- Regarding No Objection Certificate from Fire Safety Point of View.

Sir,

This is in reference to your letter no.- Nil dated- Nil on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above-mentioned school from fire safety point of view in presence of Mrs. Rajeshwari (Vice-Principal). During the course of inspection, the following points / shortcomings were noticed: -

1. The school building is not accessible to fire engines. ✓

In view of above, the school building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Rajesh Panwar)
Dy. Chief Fire Officer
Delhi Fire Service

o/c by

Copy to:-

The Dy. Director Education,
B-Block Yamuna Vihar,
Delhi-110053