

12

c 23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/ 127

Dated: 21/03/2022

To

The Principal,
Jhoom Kaur Memorial Public School,
A-365, Durga Vihar, New Delhi-110080.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Jhoom Kaur Memorial Public School, located at A-365, Durga Vihar, New Delhi-110080.**

Sir,

With reference to letter no. nil dated 31.01.2022 on the subject cited above, it is informed that the said school was granted Fire Safety Certificate (FSC) vide letter no. F6/DFS/MS/School/2019/SZ/362 dated 08.02.2019 for ground + 01 upper floor. The school building was visited by Assistant Divisional Officer (M. Road) from this department on 25.02.2022 in the presence of Mrs. Neelam Devi, care taker and it was observed that the building is now comprised of basement + ground + 1 upper floor. This amounts to substantial addition/alteration in the building. Hence FSC as per the previous fire safety norms cannot be considered.

The applicant may be requested to forward the as built building plans through the building department for reconsideration from fire safety point of view.

In view of above, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Ajay Garg)
Director

Delhi Fire Service

etc [Signature]
21/3

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.